

Necessary documents required for first time charging of transmission element

1. Formats compliance (A1-A5, B1-B5)
2. Recommendation of concerned DGM for charging of the transmission element as well as recommendation on the information in all formats covered under serial no. 1
3. Relay coordination consent from T&C /CRITIL wing.
4. Public notice published for both the ends regarding first time charging of Line.
5. Clearance from Electrical inspector clearly indicating each transmission elements to be energized i.e. Transmission lines, Transformers. Bus, Associated bays etc.
6. Compliance of observation of electrical inspector (if any)
7. PTCC clearance for Transmission lines from concerned department.
8. Clearance from SCADA wing regarding SCADA implementation (Compliance of Data integration in SLDC Ranchi as well as ERLDC).
9. Single Line Diagram (Hard & soft copy) of GSS of both ends.
10. Implementation /commissioning of Carrier/Distance protection.
11. Hotline communication.
12. Communication with SLDC ensured.
13. Clearance from both ends of the transmission lines for final charging.